

APPENDIX 1D: SOUND TRANSMISSION RATINGS

Adjacency between spaces	STC Class – Walls	STC Class - Floors
Between client rooms	45	50
Between exam rooms	45	50
Between client rooms and public spaces i.e. lobby, staff, activity room (excludes corridor serving exam room)	45	50
Between exam rooms and adjacent corridor	45	50
Between exam rooms and service areas i.e. elevator and elevator machine room, mechanical rooms on the same floor or above client rooms, offices, care stations	50	50
Between toilet rooms and public space	45	-
Between exam rooms and conference rooms	50	-
Between conference rooms and public space	45	-
Between exam rooms and staff lounges	45	-
Between public space and staff lounges	40	-